



2023 W. 1300 N.
Farr West, UT 84404
(801) 782-3580
Fax (801) 782-3582

PLAN REVIEW

Date: August 18, 2014

Project Name: Sundown Ski Lift Replacement

Project Address: 8000 N 5100 E Eden

Contractor/Contact: Jeff Werbelow jwerbelow@elliottworkgroup.com 435-640-7002

Fee Notice:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

Status: APPROVED

Specific Comments:

1. Provide a fire extinguisher at each of the lift buildings. Fire extinguishers must be 2a10bc rated.

Every effort has been made to provide a complete and thorough review of these plans. This review DOES NOT relieve the owner, contractor and/or developer from compliance with any and all applicable codes, and standards.

Any change or revision of this plan will render this review void and will require submittal of the new, or revised, layout for fire department review. If you have any questions, please contact me at 801-782-3580.

Brandon Thueson
Fire Marshal

cc: File